

Climate 5000 M

CL5000M 125/5 E

7733701938

To the extent applicable to the product, the following data are based on the requirements of Regulation (EU) 2016/2281.

Productdata	Symbol	Unit	7733701938	
Information for air-to-air air conditioners (usage of this product for cooling purpose	s, table 11)			
model identifier of the indoor elements of the air conditioner			7733701566 (2x)	
model identifier of the indoor elements of the air conditioner			7733701564 (2x)	
model identifier of the outdoor element of the air conditioner			7733701938	
Outdoor side heat exchanger of air conditioner		air		
Indoor side heat exchanger of air conditioner		air		
Туре		vapour compression		
Driver of compressor		electric motor		
Rated cooling capaciy	P _{rated,c}	kW	12,8	
Design load Pdesignc	Pdesignc	kW	12,8	
Seasonal space cooling energy efficiency	$\eta_{s,c}$	%	276,0	
Seasonal energy efficieny ratio	SEER		7,0	
Declared cooling capacity for part load at given outdoor temperatures Tj and indoor	27°/19°C (dry/wet bulb)	•	
Declared capacity for cooling at indoor 27(19) °C and outdoor 35 °C	Pdc	kW	12,8	
Declared capacity for cooling at indoor 27(19) °C and outdoor 30 °C	Pdc	kW	9,1	
Declared capacity for cooling at indoor 27(19) °C and outdoor 25 °C	Pdc	kW	6,0	
Declared capacity for cooling at indoor 27(19) °C and outdoor 20 °C	Pdc	kW	3,3	
Degradation co-efficient cooling	Cdc		2,5	
Declared energy efficiency ratio or gas utilisation efficiency/auxiliary energy factor	for part load at given ou	tdoor Tempe	eratures Tj	
Declared energy efficiency ratio at indoor 27(19) °C and outdoor 35 °C	EERd		3,4	
Declared energy efficiency ratio at indoor 27(19) °C and outdoor 30 °C	EERd		4,8	
Declared energy efficiency ratio at indoor 27(19) °C and outdoor 25 °C	EERd		7,7	
Declared energy efficiency ratio at indoor 27(19) °C and outdoor 20 °C	EERd		15,2	
Power consumption in modes other than active mode				
Off mode	P _{OFF}	kW	0,000	
Thermostat-off mode	P _{TO}	kW	0,000	
Crankcase heater mode	P _{CK}	kW	0,000	
In standby mode	P _{SB}	kW	0,000	
Other items				
Capacity control			variable	
Sound power level, outdoor	L _{WA}	dB	70,0	
Sound power level, indoor	L _{WA}	dB	56,0	
Air flow rate, outdoor measured	m³/h	m³/h	3850	
		,		

Refrigerant leakage contributes to climate change. Refrigerant with lower global warming potential (GWP) would contribute less to global warming than a refrigerant with higher GWP, if leaked to the atmosphere. This appliance contains a refrigerant fluid with a GWP equal to 675 kgCO_{2 eq}. This means that if 1 kg of this refrigerant fluid would be leaked to the atmosphere, the impact on global warming would be 675 times higher than 1 kg of CO₂, over a period of 100 years. Never try to interfere with the refrigerant circuit yourself or disassemble the product yourself and always ask a professional.



Climate 5000 M

CL5000M 125/5 E

7733701938

To the extent applicable to the product, the following data are based on the requirements of Regulation (EU) 2016/2281.

Productdata	Symbol	Unit	7733701938
Information for heat pumps (usage of this product for heating purposes, table 14)			
Outdoor side heat exchanger of air conditioner	air		
Indoor side heat exchanger of air conditioner	air		
Equipped with a supplementary heater?	Yes		
Driver of compressor	electric motor		otor
Rated heating capacity	P _{rated,h}	kW	12,3
Design load average climate	Pdesignh	kW	10,4
Seasonal space heating energy efficiency	$\eta_{s,h}$	%	151,0
SCOP/A average climate	SCOP/A		3,9
Declared heating capacity for part load at indoor temperature 20°C and outdoor temperature Tj			
Declared capacity for heating (average season) at indoor 20 °C outdoor -7 °C	Pdh	kW	9,0
Declared capacity for heating (average season)) at indoor 20 °C outdoor 2 °C	Pdh	kW	5,6
Declared capacity for heating (average season) at indoor 20 °C outdoor 7 °C	Pdh	kW	3,6
Declared capacity for heating (average season) at indoor 20 °C outdoor 12 °C	Pdh	kW	4,2
Declared capacity for heating (average season) at indoor 20 °C outdoor bivalent temperature	Pdh	kW	9,0
Declared capacity for heating (average season)) at indoor 20 °C outdoor operating limit	Pdh	kW	8,8
Bivalent temperature heating - average	Tbiv	°C	-7
Operational limit temperature heating - average	Tol	°C	-10
Degradation co-efficient heating	Cdh		0,0
Declared coefficient of performance for part load at given outdoor temperatures Tj			
Declared coefficient of performance (average season) at indoor 20 °C outdoor -7 °C	COPd		2,7
Declared coefficient of performance (average season) at indoor 20 °C outdoor 2 °C	COPd		3,7
Declared coefficient of performance (average season) at indoor 20 °C outdoor 7 °C	COPd		4,9
Declared coefficient of performance (average season) at indoor 20 °C outdoor 12 °C	COPd		6,6
Declared coefficient of performance (average season) at indoor 20 °C outdoor bivalent temperature	COPd		2,7
Declared coefficient of performance (average season) at indoor 20 °C outdoor operating limit	COPd		2,5
Power consumption in modes other than active mode			
In off mode	P _{OFF}	kW	0,000
In thermostat-off mode	P _{TO}	kW	0,000
In crankcase heater mode	P _{CK}	kW	0,000
In standby mode	P _{SB}	kW	0,000
Supplementary heater			
Back up heating capacity at reference design conditions		kW	1,4
Type of energy input			-
Other items			
Capacity control			variable
Sound power level, outdoor	L _{WA}	dB	70,0
Sound power level, indoor	L _{WA}	dB	56,0
Emissions of nitrogen oxides (only gas- or oil fired)	NO _x	mg/kWh	-
Air flow rate, outdoor measured	m³/h	m³/h	3850
	,	,	



Climate 5000 M

CL5000M 125/5 E

7733701938

Productdata Symbol Unit 7733701938

Refrigerant leakage contributes to climate change. Refrigerant with lower global warming potential (GWP) would contribute less to global warming than a refrigerant with higher GWP, if leaked to the atmosphere. This appliance contains a refrigerant fluid with a GWP equal to $675 \text{ kgCO}_{2\text{ eq}}$. This means that if 1 kg of this refrigerant fluid would be leaked to the atmosphere, the impact on global warming would be 675 times higher than 1 kg of CO_2 , over a period of 100 years. Never try to interfere with the refrigerant circuit yourself or disassemble the product yourself and always ask a professional.